

ABOVE GROUND TANK DESIGN

# Compliance Certificate

Issued in accordance with regulations 6.23 and 17.93(1)(a) of the Health and Safety at Work (Hazardous Substances) Regulations 2017. This certificate certifies that the requirements prescribed in regulations 17.93(1)(a) for a stationary container tank or process container design compliance certificate have been met.

NAME: Hendl & Murray Engineering Limited  
ADDRESS: 103 Tawa Street  
Melville  
P O Box 5492  
Hamilton  
Ph 07 843 8233

CERTIFICATE NUMBER: CC02093  
JOB NUMBER: J25120  
TANK SERIAL NUMBER: 19928-01  
TANK ID: T402  
CAPACITY: 32,460 Litres  
TANK DESIGN CODE: API 650, Twelfth Edition, March 2013, Appendix J & S.  
MANUFACTURE YEAR: 2019

FAB NUMBER: FAB0033  
TNK NUMBER: TNK20000

DRAWING NO: 19928-01-01  
SHEETS: 1 of 1  
REVISION: C, 8/10/19  
TITLE: Arsenic Acid Storage Tank T402 - General Arrangement

DATE ISSUED: 16/01/2020  
COMMENCEMENT DATE: 16/01/2020  
EXPIRY DATE: 16/01/2030

Approved For:

The storage and transfer of arsenic acid having hazard classifications 6.1B, 6.3B, 6.4A, 6.7A, 6.8A, 6.9A, 9.1A, 9.1B, 9.1C, 9.3A, 9.4B.

References:

Maximum Safe Fill Level = 30,000 Litres.

Compliance with API650, approved for construction drawings and internal QA procedures. Recertification required following any change to the referenced contents, design, duty or drawings.



Graham Voss

Compliance Certifier Registration Number: TST000083

Stork Technical Services New Zealand Limited  
107-109 De Havilland Drive  
New Plymouth 4312  
New Zealand