

ABOVE GROUND TANK DESIGN

Compliance Certificate

Issued in accordance with regulations 6.23 and 17.93(1)(a) of the Health and Safety at Work (Hazardous Substances) Regulations 2017. This certificate certifies that the requirements prescribed in regulations 17.93(1)(a) for a stationary container tank or process container design compliance certificate have been met.

NAME: Hendl & Murray Engineering Limited
ADDRESS: 103 Tawa Street
Melville
P O Box 5492
Hamilton
Ph 07 843 8233

CERTIFICATE NUMBER: CC02094
JOB NUMBER: J25120
TANK SERIAL NUMBER: 18707-03
EQUIPMENT NUMBER: Q1TK0641
CAPACITY: 21,050 Litres
TANK DESIGN CODE: AS 1692 - 1989, Category 5
MANUFACTURE YEAR: 2017
FAB NUMBER: FAB0033
TNK NUMBER: TNK20001

DRAWING NO: 18707-03-01
SHEETS: 2
REVISION: M, 13/10/17
TITLE: 20m3 CIP Dilute Caustic Tank - General Arrangement

DATE ISSUED: 16/01/2020
COMMENCEMENT DATE: 16/01/2020
EXPIRY DATE: 16/01/2030

Approved For:

The storage and transfer of CIP caustic solution maximum 5% concentration having a hazard classification of 6.1E, 8.1A, 8.2C, 8.3A.

References:

Maximum Safe Fill Level = 20,000 Litres.

Compliance with API650, approved for construction drawings and internal QA procedures. Recertification required following any change to the referenced contents, design, duty or drawings.



Graham Voss
Compliance Certifier Registration Number: TST000083

Stork Technical Services New Zealand Limited
107-109 De Havilland Drive
New Plymouth 4312
New Zealand